
VZXF-L-M22C-M

Angle seat valve



FESTO Festo SE & Co. KG

Festo SE & Co. KG Ruiter Straße 82 73734 Esslingen Germany +49 711 347-0

www.festo.com

Operating instruction 8092242 2018-06b [8092244]



Translation of the original instructions

© 2024 all rights reserved to Festo SE & Co. KG

1 About this document

This document describes the use of the above-mentioned product.

1.1 Further applicable documents



All available documents for the product → www.festo.com/pk.

2 Safety

2.1 General safety instructions

- Only use the product in original status without unauthorised modifications.
- Only use the product if it is in perfect technical condition.
- Observe labelling on the product.
- Use the valve only in the flow direction indicated.
- Take into consideration the ambient conditions at the location of use.

Media

- Only use media in accordance with the specifications \rightarrow 14 Technical data.
- Do not operate the product with chemically unstable gases, abrasive media or solid materials.
- If water is used: up to approx. 1000 ppm of chloride content is permitted. Avoid tensile stresses.
- If aggressive media are used: limit temperature of medium to 65 °C.

Return to Festo

Hazardous substances can endanger the health and safety of personnel and cause damage to the environment. To prevent hazards, the product should only be returned upon explicit request by Festo.

- Consult your regional Festo contact.
- Complete the declaration of contamination and attach it to the outside of the packaging.
- Comply with all legal requirements for the handling of hazardous substances and the transport of dangerous goods.

2.2 Intended use

The VZXF angle seat valve is intended to control gaseous or liquid media in rigid piping systems.

 To control liquid media, use only the product variant VZXF-L-M22C-M-B-... (closing against the direction of medium flow).

2.3 Training of qualified personnel


Work on the product should only be conducted by qualified personnel. The qualified personnel must be familiar with installation of process automation systems.

3 Further information

- Accessories → www.festo.com/catalogue.
- Spare parts → www.festo.com/spareparts.

4 Service

Contact your regional Festo contact person if you have technical questions → www.festo.com.



4 Arrow for direction of flow5 Operating medium port

- Actuator
- 3 Pipe connection with female thread; feed or forwarding (corresponding to flow direction)

5.2 Product variants and type code

i

The following section explains selected product characteristics that are necessary to understand the instruction manual. Description of the complete type code → www.festo.com/catalogue.

Characteristic	Value	Description
Туре	VZXF	Angle seat valve, externally controlled
Valve type	L	In-line valve
Valve function	M22C	2/2-way valve, normally closed
Reset method	м	Mechanical spring
Flow direction	A	Over valve seat, for gaseous media
	В	Under valve seat, for gaseous and liquid media
Cable connection	G12 G2	Thread G1/2" G2"
	N12 N2	Thread NPT1/2" NPT2"
Nominal width	120 450	12 mm 45 mm
Temperature range of	-	-10 +80 °C (standard)
medium	M1	-40 +200 °C
Housing material	H3	Red brass
	V4	Stainless steel
Actuator housing material	AL, AN, B1, B2, V4	Aluminium; nickel-plated aluminium; brass; nickel- plated brass; stainless steel
Stem seal material	–, T, V	Standard (NBR), PTFE, FPM
Actuator size	50,80	50 mm, 80 mm
Medium pressure	3 40	0 3 bar, , 0 40 bar
	V	–0.9 0 bar
PWIS content	-, C	Standard, PWIS-free

Tab. 1: Description of key features

5.3 Function

The angle seat valve VZXF-L-M22C-M-.... is an externally controlled 2/2-way valve. At rest, the valve is closed by spring force (normally closed - NC). If the actuator is pressurised with operating pressure, it raises the control piston and simultaneously the valve disc. The valve opens.

The valve seat is slanted around 45° toward the media flow.

The supply of the operating medium is controlled by an external valve that must be additionally integrated into the supply cable for the actuator.




Fig. 2: Circuit symbol

6 Transport and storage

- For delivery of used products: Comply with all legal requirements for the handling of hazardous substances and the transport of dangerous goods. For returns to Festo → 2 Safety.
- Store the product in a cool, dry, UV-protected and corrosion-protected environment. Ensure that storage times are kept to a minimum.

7 Assembly and installation

Requirements

NOTICE

Avoid mechanical stresses on the valve. Do not use the actuator as a lever.

- The piping is unpressurized, and no medium flows in it.

- The line ends are mounted.
- Connecting cables and fittings are clean.
- An additional 3/2-way valve is built into the supply cable of the operating medium.

i

Recommendation: For gentle operation, install a flow control valve (1.5 mm) in the supply cable of the operating medium.

Cleaning the valve

 Remove all transport packaging. The material used in the packaging has been specifically chosen for its recyclability (exception: oil-impregnated paper = residual waste).

Traces of residual grease may be evident on the product due to the production process used.

Clean the valve immediately before installation.

Connect lines

1. Bring the valve into its mounting position.

- Observe the flow direction. The permitted direction of flow is marked by an arrow on the valve housing \rightarrow Fig. 1, [4].
- Connect the piping on the valve housing.
- − Tightening torque → Tab. 2 Tightening torque pipe connection.
- 3. Connect the operating medium line.
- Tightening torque: max. 26 Nm

Connection size	["]	1⁄2	3⁄4	1	1¼	11⁄2	2
Max. tightening torque pipe connection	[Nm]	105	200	350	450	540	620

Tab. 2: Tightening torque pipe connection

8 Commissioning

Requirements

- The valve is fully mounted and connected.

Checking operating conditions

- 1. Check operating conditions and limit values \rightarrow 14 Technical data.
- 2. Check connection points for tightness.
- 3. Check compatibility of the devices in the system for maximum pressure (consider pressure peaks). If necessary, adjust the application parameters.

Commissioning the valve

- 1. Supply medium.
- Slowly apply operating pressure to the valve. The operating pressure required for reliable switching of the valve depends on the medium pressure → 14.2 Technical data, pneumatic.
 - ✤ The valve opens.

9 Operation

WARNING

Risk of injury from touching hot surfaces.

Valve housing and actuator can become hot at high temperature of medium. Severe burns are possible.

- Do not touch the angle seat valve during operation or immediately afterward.
- Comply with operating conditions.
- Comply with maintenance conditions \rightarrow 10 Maintenance, \rightarrow 10.1.

After longer idle times:

Actuate the valve several times and check for correct function.

10 Maintenance

Risk of injury from touching hot surfaces.

Valve housing and actuator can become hot at high temperature of medium. Severe burns are possible.

- Allow the angle seat valve to cool off before working on it.
- Check product regularly from the outside for leakage and function.
- Check function of the product regularly.
- Clean product regularly with commercial cleaning agents.

11 Malfunctions

Fault description	Cause	Remedy
The valve does not close.	The valve is faulty.	Replace the valve.
	The flow direction is incorrect	Replace the valve.

Fault description	Cause	Remedy	
The valve does not close.	Operating pressure is still present or is too high	Check operating pressure and adjust it, if necessary.	
The valve does not open.	The valve is faulty.	Replace the valve.	
	Medium pressure is too high.	Adjust medium pressure.	
	Operating pressure is too low.	Check operating pressure and adjust it, if necessary.	
Medium leaks from a leakage hole.	The valve is faulty.	Replace the valve.	

Tab. 3

12 Disassembly

WARNING

Risk of injury from combustion and chemical burns.

The media in the piping system and the valve can be hot and under pressure. Traces of medium can remain in the product and can escape when open or dismantled.

- Allow the valve and piping to cool and depressurize them.
- Wear specified protective equipment.

NOTICE

The disassembly of the actuator and valve body is not permitted.

- 1. Depressurise the piping and the connecting cable of the operating medium. Allow the valve and piping to cool.
- 2. Empty the piping and valve completely.
- Make sure no one is located in front of the outlet opening.
 Catch discharging media in a suitable container.
- 3. Disconnect the connecting cable of the operating medium from the valve.
- 4. Disconnect the piping connections and remove the valve.

13 Disposal

 Dispose of the product in an environmentally friendly manner. In doing so, take the remaining media into account (use of problematic materials if applicable)
 Observe the local regulations for environmentally friendly disposal.

14 Technical data

14.1 Technical data, general

Туре		VZXF-L-M22C-M				
Design		Piston actuator with poppet valve				
Actuation type		Pneumatic				
Sealing principle		Soft				
Mounting position		Any				
Type of mounting		In-line installation				
Valve function		2/2-way, closed, monostable				
Flow direction		Non-reversible				
Exhaust function		Without flow control option				
Reset method		Mechanical spring				
Type of control		Externally controlled				
Product weight		→ www.festo.com/catalogue				
CE marking		In accordance with declaration of conformity → www.festo.com/sp				
Medium						
Medium VZXFA		Compressed air grade of filtration 200 μm , inert gases, vapour $^{1)}$				
Medium VZXFB		Compressed air grade of filtration 200 µm, inert gases, water, neutral liquid media, petroleum, petroleum based hydraulic fluid, vapour ¹⁾				
Medium pressure	[bar]	-0,9 40, in accordance with information on product labelling				
Viscosity	[mm ² /s]	≤600				
Operating medium						
Operating medium		Compressed air to ISO 8573-1:2010 [7:4:4]				
Operating pressure	[bar]	6 10 → 14.2 Technical data, pneumatic				
Temperature						
Temperature of medium (NBR, FKM)	[°C]	-10 +80				
Temperature of medium (PTFE)	[°C]	-40 +200				
Perm. min./max. temp (TS) (NBR, FKM)	[°C]	-10 +80				
Ambient temperature	[°C]	-10 +60				
Note on materials		·				
VZXFH3AL		Housing: red brass; actuator: aluminium				
VZXFH3B1		Housing: red brass; actuator: brass				
VZXFV4AN		Housing: stainless steel; actuator: nickel-plated alumi- nium				

Type VZXF-L-M22C-M					
VZXFV4B2	Housing: stainless steel; actuator: nickel-plated brass				
VZXFV4V4	Housing: stainless steel; actuator: stainless steel				
Stem seal	NBR (standard), PTFE, FKM				
Seat seal	PTFE (standard) FKM (vacuum design, PWIS-free)				

1) other media on request

Tab. 4: Technical data, general, VZXF

14.2 Technical data, pneumatic


Nominal pressure and flow rate of process valve


Connection size	["]	1⁄2	3/4	1	11⁄4	11⁄2	2
Pipe thread in accordance with DIN ISO 228		G1⁄2	G¾	G1	G1¼	G1½	G2
Pipe thread in accordance with ANSI B 1.20.1		NPT 1/2	NPT 3/4	NPT 1	NPT 11⁄4	NPT 11/2	NPT 2
Pneumatic connection		G1⁄8					
Connection size DN		15	20	25	32	40	50
Nominal pressure of process valve PN VZXFH3	[bar]	16					
Nominal pressure of process valve PN VZXFV4	[bar]	40					
Flow rate K _v ¹⁾							
VZXFAH350	[m³/h]	3.5	6.7	10.8	19	23	28
VZXFBH350	[m³/h]	3.7	5.2	9.6	6	16.5	23
VZXFAV450	[m³/h]	3.8	7.5	12	18.5	25	34.5
VZXFBV450	[m ³ /h]	3.3	6.5	11	10.7	17.5	19.5
VZXFAH380	[m ³ /h]	-	-	12	21.5	30.5	40
VZXFBH380	[m ³ /h]	-	-	14.5	19	29.5	30
VZXFAV480	[m ³ /h]	-	-	12.5	19	29	47.5
VZXFBV480	[m ³ /h]	-	-	12	17.5	28	39


1) water, at + 20 °C, medium pressure 1 bar at the valve input, free outlet


Tab. 5: Technical data, pneumatic, VZXF


Operating pressure and medium pressure VZXF-...-A-... (medium flow under valve seat)














 Fig. 6: Operating pressure and medium pressure VZXF-...-A-...-V4V4-...-80

 p1
 Medium pressure

 p2
 Operating pressure

Operating pressure and medium pressure VZXF-...-B (medium flow under valve seat)

VZXF		DN15	DN20	DN25	DN32	DN40	DN50
VZXFBH350							
Min. operating pressure	[bar]	4.9	4.5	5.3	5.5	5.8	5.7
Max. medium pressure	[bar]	16	16	10	7	6	3
VZXFBV450							
Min. operating pressure	[bar]	5.3	5.5	5.5	5.5	5.5	5.5
Max. medium pressure	[bar]	40	20	10	7	6	3
VZXFBH380							
Min. operating pressure	[bar]	-	-	4.0	4.2	4.3	4.3
Max. medium pressure	[bar]	-	-	16	12	8	5
VZXFBV480							
Min. operating pressure	[bar]	-	-	4.1	4.1	4.1	4.1
Max. medium pressure	[bar]	-	-	22	10	8	5

Tab. 6: Operating pressure and medium pressure, VZXF-...-B